

MHD Contractor Performance: October - December 2014

CONTRACTOR	UNITS COMPLETED	* % OF RE-WIPES TAKEN	LEAD SAFETY VIOLATIONS ISSUED	* PERMIT EXTENSIONS	OPEN COMPLAINTS
A & G	0	0.0%	0	0	NO
ARL	12	1.8%	0	2	NO
C & E	15	0.0%	0	0	NO
C & M	4	2.2%	0	0	NO
EPM	0	0.0%	0	0	NO
FAQ	11	0.0%	0	0	NO
GET	1	0.0%	0	0	NO
MCM	13	0.0%	0	0	NO
MEDINA	7	0.0%	0	2	NO
POWER	0	0.0%	0	0	NO
RIGHT PRICE	6	4.3%	0	2	NO

*** % OF REWIPES TAKEN** - At the end of the project a dust test is done for occupant safety. When a contractor leaves too much leaded dust behind, (measured by lab analysis) he must return to the property for a second cleaning on surfaces where he failed the dust test. The inspector also returns to the site to take more samples to confirm safety.

***PERMIT EXTENSIONS** - Extra time given to contractor to complete the project (ORIGINAL ALOTTED TIME is 2 WEEKS).